



DEPARTMENT OF THE ARMY
ARMY NATIONAL MILITARY CEMETERIES
ARLINGTON NATIONAL CEMETERY
ARLINGTON, VIRGINIA 22211-5003

28 September 2022

SUBJECT: SANITARY SEWER REPAIR PROJECT, ARLINGTON NATIONAL CEMETERY, ARLINGTON, VIRGINIA

Arlington National Cemetery (ANC) proposes repairs to existing sanitary sewer lines. The work includes rehabilitation, cleaning, repair, and replacement of lines. The project also includes restoration of existing manholes and installation of new manholes.

The sanitary sewer system at ANC is made up of various materials such as clay, polyvinyl chloride (PVC), and high-density polyethylene (HDPE) and is of varying ages. To prevent future system failures and to prolong the life of the system, ANC seeks to have the sanitary system cleaned and repaired. The project will mainly utilize trenchless technologies, such as pipe bursting and Cured-In-Place Pipe (CIPP) lining services of existing pipes. There will be excavation in sections 41 and 49.

ANC invites review and comment from the public on this project. We do this in accordance with Section 106 of the National Historic Preservation Act and The Programmatic Agreement among Arlington National Cemetery, The Virginia State Historic Preservation Officer, and the Advisory Council on Historic Preservation for the Operation, Maintenance, and Repair Activities at Arlington National Cemetery.

The document "Sanitary Sewer Repair Project, Arlington National Cemetery, Arlington, Virginia, Project Description, Area of Potential Effects, and Assessment of Effects" accompanies this notice. It shows the area affected by the project, contains annotated photographs of those areas, illustrates the proposed work, and lists the historic properties contributing to National Register of Historic Places Historic Districts which are in the area of potential effects.

There are no known archaeological resources in the area of potential effects.

ANC's Cultural Resource Manager assessed the effects of the proposed undertaking using the criteria of adverse effects (36 C.F.R. 800.5(a)(1)) and determined the project will have *No Adverse Effect* on the characteristics which qualify Arlington National Cemetery, or the surrounding historic districts, for listing in the National Register of Historic Places.

Please send your comments to the Cultural Resources Manager at usarmy.pentagon.hqda-anc-osa.mbx.cultural-resources@army.mil and include "Sanitary Sewer Repair Project" in the subject line. Comments are due no later than October 29, 2022.

Thank you for your interest in Arlington National Cemetery.